

# ANY COMPANY LTD

## PORTABLE APPLIANCE TEST CERTIFICATE 2010

ASSET ID	DESCRIPTION	LOCATION	TEST DATE	NEXT DUE	VISUAL	BOND (mΩ)	INSULATION (MΩ)	OPERATION (kVA)	LEAKAGE (mA)	POLARITY	OVERALL STATUS
127470	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Fail	-	-	-	-	-	Fail Flex damaged
127501	HEATER	BOARD ROOM	3/14/2008	Mar-09	Pass	-	0	-	-	-	Fail Insulation test
127455	EXT	RECEPTION	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
127456	IEC LEAD	RECEPTION	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
127457	IEC LEAD	RECEPTION	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
127458	PC	RECEPTION	3/14/2008	Mar-09	Pass	0.06	-	0.02	0.33	-	Pass
127459	VDU	RECEPTION	3/14/2008	Mar-09	Pass	0.14	-	0.03	0.54	-	Pass
127460	FAN	RECEPTION	3/14/2008	Mar-09	Pass	0.11	>50	0.02	0	-	Pass
127461	EXT	RECEPTION	3/14/2008	Mar-09	Pass	0.09	>50	-	-	OK	Pass
127462	EXT	RECEPTION	3/14/2008	Mar-09	Pass	0.12	>50	-	-	OK	Pass
127463	IEC LEAD	RECEPTION	3/14/2008	Mar-09	Pass	0.12	>50	-	-	OK	Pass
127464	SHREDDER	RECEPTION	3/14/2008	Mar-09	Pass	0.14	>50	0	0	-	Pass
127465	IEC LEAD	RECEPTION	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
127466	COPIER	RECEPTION	3/14/2008	Mar-09	Pass	0.07	-	0.02	0.22	-	Pass
127467	EXT	RECEPTION	3/14/2008	Mar-09	Pass	0.09	>50	-	-	OK	Pass
127468	FAN	RECEPTION	3/14/2008	Mar-09	Pass	0.11	>50	0.03	0	-	Pass
127469	FAN	RECEPTION	3/14/2008	Mar-09	Pass	-	>50	0.02	0	-	Pass
127471	IEC LEAD	RECEPTION	3/14/2008	Mar-09	Pass	0.06	>50	-	-	OK	Pass
127472	PRINTER	RECEPTION	3/14/2008	Mar-09	Pass	0.1	-	0.1	0.39	-	Pass
127473	IEC LEAD	RECEPTION	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
127474	PRINTER	BOARD ROOM	3/14/2008	Mar-09	Pass	0.07	-	0.2	0.31	-	Pass
127475	IEC LEAD	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127476	ADAPTOR	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127477	IEC LEAD	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127478	IEC LEAD	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127479	IEC LEAD	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127480	ADAPTOR	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127481	VDU	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127482	PC	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127483	IEC LEAD	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127484	SWITCH	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127485	PRINTER	BOARD ROOM	3/14/2008	Mar-09	Pass	-	-	-	-	-	Pass
127486	FAN	BOARD ROOM	3/14/2008	Mar-09	Pass	0.12	>50	0.02	0	-	Pass
127487	FAN	BOARD ROOM	3/14/2008	Mar-09	Pass	-	>50	0.02	0	-	Pass

127488	BINDER	BOARD ROOM	3/14/2008	Mar-09	Pass	0.11	>50	0.28	0	-	Pass
127489	IEC LEAD	BOARD ROOM	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
127490	IEC LEAD	IT	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
127491	EXT	IT	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
127492	EXT	IT	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
127493	FAN	IT	3/14/2008	Mar-09	Pass	0.13	>50	0.03	0	-	Pass
127494	IEC LEAD	IT	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
127495	POST MACHINE	IT	3/14/2008	Mar-09	Pass	0.06	-	0.02	0.4	-	Pass
127496	EXT	IT	3/14/2008	Mar-09	Pass	0.26	>50	-	-	OK	Pass
127497	IEC LEAD	IT	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
127498	EXT	ACCOUNTS	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
127499	IEC LEAD	ACCOUNTS	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
127500	COPIER	ACCOUNTS	3/14/2008	Mar-09	Pass	0.06	-	1.05	0.72	-	Pass
127502	ADAPTOR	ACCOUNTS	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
127503	EXT	ACCOUNTS	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
127504	IEC LEAD	ACCOUNTS	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
127505	IEC LEAD	ACCOUNTS	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
127506	PC	ACCOUNTS	3/14/2008	Mar-09	Pass	0.12	-	0.04	0.28	-	Pass
127507	VDU	ACCOUNTS	3/14/2008	Mar-09	Pass	0.22	-	0.02	0.35	-	Pass
127508	LEAD	ACCOUNTS	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
127509	FRIDGE	ACCOUNTS	3/14/2008	Mar-09	Pass	-	>50	0.05	0	-	Pass
127510	ADAPTOR	ACCOUNTS	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
127511	XMAS LIGHTS	ACCOUNTS	3/14/2008	Mar-09	Pass	-	>50	0.01	0	-	Pass
124459	EXT LEAD	KITCHEN	3/14/2008	Mar-09	Pass	0.21	>50	-	-	OK	Pass
124460	IEC LEAD	KITCHEN	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124461	HUB	KITCHEN	3/14/2008	Mar-09	Pass	-	-	0.03	0.31	-	Pass
124462	IEC LEAD	KITCHEN	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124463	IEC LEAD	KITCHEN	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
124464	MONITOR	KITCHEN	3/14/2008	Mar-09	Pass	0.21	-	0	0.54	-	Pass
124465	FAN	KITCHEN	3/14/2008	Mar-09	Pass	-	>50	0.02	0	-	Pass
124466	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
124467	FIG 8 LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
124468	TRANSFORMER	WAREHOUSE	3/14/2008	Mar-09	Pass	-	-	0	0	-	Pass
124469	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.09	>50	-	-	OK	Pass
124470	MONITOR	WAREHOUSE	3/14/2008	Mar-09	Pass	0.38	-	0.02	0.5	-	Pass
124471	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124472	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.09	-	0.04	0.36	-	Pass
124473	HEATER	WAREHOUSE	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
124474	AIR FAN	WAREHOUSE	3/14/2008	Mar-09	Pass	-	>50	0.04	0	-	Pass
124475	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.13	>50	-	-	OK	Pass
124476	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
124477	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.16	>50	-	-	OK	Pass
124478	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124479	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124480	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.06	>50	-	-	OK	Pass
124481	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124482	MONITOR	WAREHOUSE	3/14/2008	Mar-09	Pass	0.3	-	0.02	0.4	-	Pass

124483	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.06	-	0	0.62	-	Pass
124484	MONITOR	WAREHOUSE	3/14/2008	Mar-09	Pass	0.08	-	0	0.76	-	Pass
124485	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	-	0.06	0.52	-	Pass
124486	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.1	-	0.04	0.33	-	Pass
124487	SCANNER	WAREHOUSE	3/14/2008	Mar-09	Pass	-	-	0	0	-	Pass
124488	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.12	>50	-	-	OK	Pass
124489	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.08	>50	-	-	OK	Pass
124490	VOICE REC	WAREHOUSE	3/14/2008	Mar-09	Pass	-	-	0	0	-	Pass
124491	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124492	MONITOR	WAREHOUSE	3/14/2008	Mar-09	Pass	0.09	-	0	0.49	-	Pass
124493	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	-	0.04	0.37	-	Pass
124494	HEATER	WAREHOUSE	3/14/2008	Mar-09	Pass	0.08	>50	0	0	-	Pass
124495	KETTLE	WAREHOUSE	3/14/2008	Mar-09	Pass	0.04	>50	0	0	-	Pass
124496	KETTLE	WAREHOUSE	3/14/2008	Mar-09	Pass	0.05	>50	0	0	-	Pass
124497	MICROWAVE	WAREHOUSE	3/14/2008	Mar-09	Pass	0.04	>50	0	0.47	-	Pass
124498	FRIDGE	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	-	Pass
124499	WATER COOLER	WAREHOUSE	3/14/2008	Mar-09	Pass	0.1	>50	0.18	0	-	Pass
124500	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.11	>50	-	-	OK	Pass
124501	EXT LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.12	>50	-	-	OK	Pass
124502	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.09	>50	-	-	OK	Pass
124503	PRINTER	WAREHOUSE	3/14/2008	Mar-09	Pass	-	>50	0.31	0.24	-	Pass
124504	EXT	WAREHOUSE	3/14/2008	Mar-09	Pass	0.12	>50	-	-	OK	Pass
124505	EXT	WAREHOUSE	3/14/2008	Mar-09	Pass	0.09	>50	-	-	OK	Pass
124506	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.09	>50	-	-	OK	Pass
124777	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124778	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.06	>50	-	-	OK	Pass
124779	EXT	WAREHOUSE	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
124780	VDU	WAREHOUSE	3/14/2008	Mar-09	Pass	0.15	-	0.02	0.46	-	Pass
124781	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.18	-	0.04	0.32	-	Pass
124782	PRINTER	WAREHOUSE	3/14/2008	Mar-09	Pass	0.06	-	0.3	0.19	-	Pass
124783	ADAPTOR	WAREHOUSE	3/14/2008	Mar-09	Pass	-	-	0	0	-	Pass
124784	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124785	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124786	EXT	WAREHOUSE	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
124787	IEC LEAD	WAREHOUSE	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124788	PRINTER	WAREHOUSE	3/14/2008	Mar-09	Pass	0.1	-	0.29	0.21	-	Pass
124789	PC	WAREHOUSE	3/14/2008	Mar-09	Pass	0.12	-	0.04	0.31	-	Pass
124790	VDU	WAREHOUSE	3/14/2008	Mar-09	Pass	0.27	-	0.03	0.49	-	Pass
124791	HEATER	BUILDING 12	3/14/2008	Mar-09	Pass	-	>50	1.87	0	-	Pass
124792	DESK FAN	BUILDING 12	3/14/2008	Mar-09	Pass	0.1	>50	0.03	0	-	Pass
124793	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.06	>50	-	-	OK	Pass
124794	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124891	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.08	>50	-	-	OK	Pass
124892	EXT	BUILDING 12	3/14/2008	Mar-09	Pass	0.12	>50	-	-	OK	Pass
124893	PC	BUILDING 12	3/14/2008	Mar-09	Pass	0.14	-	0.04	0.28	-	Pass
124894	VDU	BUILDING 12	3/14/2008	Mar-09	Pass	0.15	-	0.03	0.35	-	Pass
124895	FIG 8 LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass

Any Company PAT Certificate 2008

engineer: G.Arbones

124896	TRANSFORMER	BUILDING 12	3/14/2008	Mar-09	Pass	-	-	0	0	-	Pass
124897	TRANSFORMER	BUILDING 12	3/14/2008	Mar-09	Pass	0.13	-	0	0.11	-	Pass
124898	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.08	>50	-	-	OK	Pass
124899	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.07	>50	-	-	OK	Pass
124900	PC	BUILDING 12	3/14/2008	Mar-09	Pass	0.07	-	0.04	0.28	-	Pass
124901	VDU	BUILDING 12	3/14/2008	Mar-09	Pass	0.2	-	0.03	0.33	-	Pass
124902	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.1	>50	-	-	OK	Pass
124903	VDU	BUILDING 12	3/14/2008	Mar-09	Pass	0.31	-	0.03	0.31	-	Pass
124904	PC	BUILDING 12	3/14/2008	Mar-09	Pass	0.14	-	0.04	0.27	-	Pass
124905	FIG 8 LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
124906	TRANSFORMER	BUILDING 12	3/14/2008	Mar-09	Pass	-	-	0	0	-	Pass
124907	PRINTER	BUILDING 12	3/14/2008	Mar-09	Pass	0.07	-	0.29	0.21	-	Pass
124098	IEC LEAD	BUILDING 12	3/14/2008	Mar-09	Pass	0.06	>50	-	-	OK	Pass
124909	VDU	BUILDING 12	3/14/2008	Mar-09	Pass	0.09	-	0	0.14	-	Pass
124910	CHRISTMAS LIGHTS	BUILDING 12	3/14/2008	Mar-09	Pass	-	>50	0	0	-	Pass
124911	PC	BUILDING 12	3/14/2008	Mar-09	Pass	0.37	-	0	0.5	-	Pass
124912	LIGHTS	BUILDING 12	3/14/2008	Mar-09	Pass	-	>50	0.02	0	-	Pass
124913	LIGHTS	BUILDING 12	3/14/2008	Mar-09	Pass	-	>50	0.03	0	-	Pass